

CLEVA POD® – H1 AS1 tables applicability

H1 AS1 tables are applicable to CLEVA POD®

You are permitted to use the H1/AS1 tables for the CLEVA POD®. I've confirmed this with MBIE, that all pod systems formed from an array of pods with ribs and without under-rib insulation are permitted to use tables F1.2.2A, F1.2.2B, F1.2.2C and F1.2.2D in H1/AS1 to determine their R-value for H1 compliance. Note these table numbers reference the 4August2022 version. Also note that where H1/AS1 says 'Concrete raft foundation' this is a 'array of pods' slab system and is local New Zealand terminology.

As always with building code compliance, MBIE has noted that the local Building Consent Assessor (BCA) can decide differently but this was what was intended for the H1/AS1 tables.



Jason Quinn CMEngNZ IntPE(USA)

Director, Sustainable Engineering Ltd.